



PUTNAM COUNTY DEPARTMENT OF HEALTH

1 Geneva Road, Brewster, NY 10509 ■ 845-808-1390

www.putnamcountyny.gov/health

A PHAB-ACCREDITED HEALTH DEPARTMENT

MaryEllen Odell
COUNTY EXECUTIVE

Michael J. Nesheiwat, MD
COMMISSIONER OF HEALTH

June 18, 2021

Lawrence Downey
58 Kingwood Drive
Poughkeepsie, NY 12601

Re: Approval of Plans for a Wastewater Treatment System
for 3622 Route 9 LLC
3622 Route 9
(T) Philipstown, T.M. 17-1-44

Dear Mr. Downey:

This office has received the engineering report, plans and application for the wastewater treatment system for the above-noted project.

Upon review, it has been determined that the submission meets the applicable criteria of the NYS Department of Environmental Conservation and the Putnam County Health Department for the design of sewage treatment systems. This approval of plans is issued under provisions of Article 3 of the Putnam County Sanitary Code, Article 17 of the Environmental Conservation Law and 6 NYCRR 652, and is issued for plans prepared by John Watson, P.E. of Insite Engineering P.C. and dated March 22, 2021.

This letter shall serve as record of approval and by initiating construction of the project covered by this approval of plans, the applicant accepts and agrees to abide by and conform to the following:


1. THAT the approval letter shall be maintained on file by the applicant.
2. THAT the approval is revocable or subject to modification or change pursuant to Article 3 of the Putnam County Sanitary Code and Article 17 of the Environmental Conservation Law.
3. THAT the facilities shall be fully constructed and completed in compliance with the engineering report and plans, as approved. The Putnam County Health Department must be notified when construction commences on the Wastewater Conveyance System, and provided with a construction schedule.
4. THAT the construction of the facilities shall be under the supervision of a person or firm licensed and registered to practice professional engineering in the State of New York under the Education Law of the State of New York, which supervision is the responsibility of the applicant.
5. THAT the design professional supervising such construction shall certify to the Department in writing, that the constructed facilities have been under his/her supervision and that the work has been fully completed in accordance with the approved engineering reports, plans, and approval of plans.
6. THAT the design professional shall submit an application for construction compliance consisting of "as-built" plan and guarantee after construction is completed together with

certification by the engineer that the sewage treatment system has been completed in conformance with the approved plans.

7. THAT occupancy of the buildings and operation of the sewage treatment system shall not be permitted until the construction compliance and authorization to operate are approved by this Department.
8. THAT the approval is valid for two (2) years and expires on June 18, 2023.
9. THAT the approval of this Department shall be secured for each change of usage to insure that the subsurface sewage treatment system maximum flow of 600 gallons per day is not exceeded.
10. THAT a master water meter shall be installed in each building and a record of daily readings be submitted to this Department monthly.
11. THAT the Health Department be notified when the construction starts on the system and also notified prior to backfill of the system.
12. THAT the wastewater facilities are to receive sanitary wastes only. The Putnam County Health Department shall be promptly notified in the event that any wastes other than strictly domestic sanitary wastes are produced at this facility.

The Department is forwarding three (3) copies of the approved construction permit and two (2) copies of the approved construction plans to your design professional. This approval of plans is issued for the construction of two 1,000 gallon septic tanks, 1,000 gallon pump chamber, 104 LF of 4 X 4 gallies and appurtenances and is issued for the State Commissioner of Environmental Conservation.

Respectfully,



Joseph S. Paravati Jr., P.E.
Public Health Engineer

JSP:cml

cc: John Watson, P.E.
BI, (T) Philipstown
NYSDEC, White Plains